

Borg Panels Community Complaints Register – October 2017

Complaint No	Category	Date	Property	Detail	Follow Up Actions
2	Water	25/10/2017	Highland Motor Inn	Town water supply dirty at Highland Motor Inn. Borg Panels ruptured the town water supply pipeline onsite causing Council lines to flush in an uncontrolled manner mobilising sediment in the lines.	Water main isolated and line repaired.