Borg Panels Pty Ltd
ABN: 54 139 584 900

Lowes Mount Rd
Oberon NSW 2787
Australia

Ph: 02 6339 6111
Fax: 02 6339 6220

EPA Point 1 - Monitoring data

Date	Op	Comments	Analyte									
			pH	TSS mg/L	True Colour	Nitrogen mg/L	Phosphorous mg/L	O & G mg/L	BOD mg/L	MBAS mg/L	Aldrin	Dieldrin
5-Mar-15	ME	No flow due to water recycling. no sample taken.										
12-Mar-15	ME	No flow due to water recycling. no sample taken.										
19-Mar-15	ME	No flow due to water recycling. no sample taken.										
25-Mar-15	ME	Recent rainfall, low flow	7.42	22	50	3	0.12	4	13	0.2	0	0
1-Apr-15	ME	No flow due to water recycling. no sample taken.										
8-Apr-15	ME	Recent rainfall, low flow	7.24	73	70	2.2	0.14	6	16	0.1	0	0
15-Apr-15	ME	No flow, no sample taken										
21-Apr-15	ME	Recent heavy rainfall, FF2 wier overflowing, Sand filter valve open	7.45	43	120	3.2	0.19	4	17	0.1	0	0
30-Apr-15	ME	Recent heavy rainfall, FF2 wier overflowing, Sand filter valve open	7.73	8	30	3.1	0.06	4	5	0.1	0	0
7-May-15	ME	Low flow water clear no odur or solids	7.91	12	30	3.2	0.07	4	1	0.1	0	0
14-May-15		No flow, no sample taken										
21-May-15		No flow, no sample taken										
28-May-15			7.5	21	45	10.1	0.08	<5	8	0.1	0	0
4-Jun-15		No flow, no sample taken										
11-Jun-15		No flow, no sample taken										
18-Jun-15		No flow, no sample taken										
25-Jun-15			7.66	10	35	3.4	.0.07	<5	12	0.3	0	0
2-Jul-15		No flow, no sample taken										
9-Jul-15		No flow, no sample taken										
16-Jul-15		No flow, no sample taken										
23-Jul-15		No flow, no sample taken										
30-Jul-15			8.14	7	55	2.9	0.04	<5	6	<0.1	<0.01	<0.01
6-Aug-15			7.9	20	45	2.7	0.05	<5	5	<0.1	<0.01	<0.01
13-Aug-15			7.83	17	40	1.2	0.04	<5	<2	<0.1	<0.01	<0.01
20-Aug-15			7.44	35	75	2.5	0.12	<5	17	<0.1	<0.01	<0.01
27-Aug-15			7.65	9	112	2.2	0.12	<5	3	0.1	<0.01	<0.01
3-Sep-15			7.37	73	62	2	0.12	<5	15	0.1	<0.01	<0.01
9-Sep-15			7.62	8	55	2.2	.0.3	<5	39	0.1	<0.01	<0.01
17-Sep-15			8.1	6	50	1.3	0.05	4	1	0.1	0	0
24-Sep-15		No flow, no sample taken										
30-Sep-15	AF	Clear sunny day. FF2 draining, sand filter blocked	8.06	15	50	6.7	0.1	6	16	0.1	0	0
7-Oct-15	AF		8.12	9	60	6.8	0.06	4	8	0	0	0
15-Oct-15	AF		7.8	18	100	4.5	0.08	4	15	0.1	0	0
22-Oct-15	AF		7.82	20	62	3.1	0.09	6	5	0.1	0	0
29-Oct-15	AF	No flow, no sample taken										
5-Nov-15	AF		7.73	12	80	3.1	0.12	4	8	0.1	0	0
12-Nov-15	AF		7.89	6	75	4	0.05	4	6	0.1	0	0
19-Nov-15												
25-Nov-15	AF	Clear, sunny day. No recent rainfall Water in catchment dam clear, no odour. FF2 below level or sand filter valve therefore not overflowing.	8.09	4	55	2.5	0.05	4	4		0	0
3-Dec-15	AF		7.85	32	40	1.7	0.06	4	1	0.1	0	0
10-Dec-15		No flow, no sample taken										
16-Dec-15			7.56	18	40	2.8	0.06	4	1	0	0	0
23-Dec-15		No flow, no sample taken										
30-Dec-15		No flow, no sample taken										
6-Jan-16		No flow, no sample taken										
13-Jan-16		No flow, no sample taken										
20-Jan-16		No flow, no sample taken										
27-Jan-16		No flow, no sample taken										
4-Feb-16	AF		7.67	6	35	1.7	0.08	4	1	0.1	0	0
11-Feb-16	AF	No flow, no sample taken										
18-Feb-16	AF	No flow, no sample taken										
25-Feb-16	AF	No flow, no sample taken										
3-Mar-16	AF	No flow, no sample taken										
10-Mar-16	AF	No flow, no sample taken										
17-Mar-16	AF	No flow, no sample taken										
24-Mar-16	AF	No flow, no sample taken										
31-Mar-16	ME	No flow, no sample taken										