

ENVIRONMENT PROTECTION LICENCE 3035

OCTOBER 2018 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
08-OCT	<0.01	<2	75	<0.01	<0.1	3.7	<5	7.8	0.06	18	N
11-OCT	<0.01	3	40	<0.01	<0.1	4.6	<5	7.53	0.05	43	N
16-OCT	<0.01	<2	60	<0.01	<0.1	5.8	<5	7.58	0.1	31	N
24-OCT	<0.01	<2	25	<0.01	0.1	8.2	<5	7.41	0.1	13	N
30-OCT	<0.01	<2	75	<0.01	0.1	6	<5	7.77	0.06	13	N

EXCEEDANCES