

ENVIRONMENT PROTECTION LICENCE 3035

NOVEMBER 2018 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
05-NOV	<0.01	<2	110	<0.01	0.2	4.2	<5	7.51	0.08	23	N
12-NOV	<0.01	3	110	<0.01	<0.01	9.9	<5	7.74	0.1	19	N
26-NOV	<0.01	3	55	<0.01	<0.01	3.9	<5	7.64	0.02	6	N