

ENVIRONMENT PROTECTION LICENCE 3035

January 2023 Surface Water Quality Monitoring

LIMITS

ANALYTE								pH	Total P	TSS
	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease			
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									

RESULTS EPA point 28

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
No samples taken for January as water was not discharging.											