

ENVIRONMENT PROTECTION LICENCE 3035

November 2022 Surface Water Quality Monitoring

LIMITS

ANALYTE								pH	Total P	TSS
	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease			
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									

RESULTS EPA point 28

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
3/11/2022	<0.010	<2	35	<0.010	<0.1	6.9	<5	7.15	0.07	36	N
9/11/2022	<0.010	6	50	<0.010	<0.1	8.6	<5	7.9	0.09	6	N
16/11/2022	<0.010	3	40	<0.010	<0.1	7.2	<5	7.71	0.05	16	N
23/11/2022	<0.010	6	50	<0.010	<0.1	7	<5	7.75	0.07	<5	N