

## ENVIRONMENT PROTECTION LICENCE 3035

### OCTOBER 2019 Surface Water Quality Monitoring

#### LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

#### RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
11/10/2019	<0.010	<2	40	<0.010	<0.1	3.2	<5	7.7	0.05	<5	N
18/10/2019	<0.010	3	45	<0.010	<0.1	2.5	<5	7.87	0.05	18	N

**No further monitoring conducted during October 2019 due to no flow/no discharge from site**