

## ENVIRONMENT PROTECTION LICENCE 3035

### FEBRUARY 2020 Surface Water Quality Monitoring

#### LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

#### RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
11/02/2020	<0.010	3	40	<0.010	0.1	2.4	<5	7.13	0.17	88	Y
19/02/2020	<0.010	<2	50	<0.010	0.2	2.4	<5	7.62	0.14	12	N