Borg Panels Pty Ltd
ABN: 54 139 584 900

Lowes Mount Rd
Oberon NSW 2787
Australia

Ph: 02 6339 6111
Fax: 02 6339 6220

ENVIRONMENT PROTECTION LICENCE 3035

JANUARY 2022 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									

RESULTS EPA point 28

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
25/01/2020	<0.010	<2	30	<0.010	<0.1	6.4	<5	7.48	0.12	14	N