

ENVIRONMENT PROTECTION LICENCE 3035

MAY 2021 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									

RESULTS EPA point 1

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
5/05/21	<0.010	6	18	<0.010	0.2	2.3	<5	7.38	0.23	290	Y

RESULTS EPA point 28

Nil discharge from Point 28 during May 2021